

Dated : 23-06-09

Place : Itanagar

Corrigendum / Addendum made out of Clarifications/ decisions taken during the Pre Bid Meeting held on June 18, 2009 at MNRE New Delhi regarding tender of small hydro power projects in Arunachal Pradesh under PM package pertaining to APEDA.

1. The EMD may be submitted in the form of Bank Guarantee also valid for one year.
2. The tender document can be downloaded after **25th June, 2009** from our website **www.apeda.co.in** containing corrigendum, addendum, etc. and may be treated as the updated & corrected one. Interested bidders may download and submit the same by due date with the tender fee.
3. The EMD shall be returned within two months to unsuccessful bidders after the placement of order.
4. The EMD of successful bidder shall be returned against submission of Performance Guarantee of the Contract.
5. The BG submitted against the advance mobilization shall be returned after the receipt of all material at site and release of second installment.
6. Effort shall be taken by the Purchaser with utmost importance and care so that the civil works are completed side by side to achieve the commissioning of the project in time.
7. There shall only be one valve as main inlet valve before inlet of the turbine and it will form part of the E & M Equipment. The schedules may be read accordingly.
8. The turbine design shall be governed with the net head and capacity of each unit / project, not discharge.
9. Under pre qualification, EPC having prescribed experience and other required qualifications may also be allowed to participate in the tender process only if their offers are supported with Memorandum of Understanding with Equipment manufacturer (on Non Judicial stamp paper of Rs 100/-).
10. Efficiency of the turbine and generator should be supported with the type testing evidences as mentioned in the tender document.

Additional Clarification / Addendum:

1. Multiple participations by one same turbine manufacturer through various outlets like Dealers, Joint Venture partners, by the Principle Manufacturer itself or by E.P.C's etc shall not be allowed and accepted. The participation has to be done through a single outlet only.
2. Price Variation Clause at Clause No.4.23 shall be treated as deleted.
3. No tender document will be sold directly from the Corporate Office of APEDA at Itanagar as announced earlier. It shall have to be downloaded from our Website – www.apeda.co.in and submitted on or before the appointed date duly signed and accompanied with Earnest Money by the interested bidders.

Cont.p/2.....

.....p/2.....

4. The Design Discharge given in the Project Details of each Project Site (Refer Tender Document) is the maximum discharge at the Forebay inlet. The Net Head or Rated Head required for designing of the turbine may be taken 10% less than the Gross Head. The design discharge of turbine may therefore be decided by the manufactures based on the Net Head and Capacity of each Project.

Sd/-
(Er. M. Loya)
Director, APEDA